



# Finally a Digital Proximity Sensor Capable of High-resolution Sensing with Unprecedented Ease

## Sensors

#### An Impressive Lineup of Sensor Heads to Handle a Wide Variety of Applications


#### An Array of Heads

The lineup includes some Sensor Heads as thin as 3-mm in diameter and others that are thin and flat. Narrow installation spaces are not a problem for these models. Still other Sensor Heads are heat resistant or rated IP67 for superior environmental resistance. These models are capable of high-resolution sensing even in harsh environments.



#### Flexible Cables Provided as a Standard Feature Industry First

With flexible cables connecting the Preamplifier to the Amplifier, installation on moving parts is never a problem. The twin-output models can also output an open-circuit alarm. In that rare instance where the cable breaks, the E2C-EDA can then send out an alarm that greatly simplifies the task of locating the faulty Sensor.






#### ■ High-resolution Sensing Unaffected by Environmental Swings Industry Leader

Excellent temperature characteristics at 0.08%/°C (5.4-mm dia. Sensor Head)

In addition to repeat accuracy of 1-µm or better, the temperature characteristics of the E2C-EDA are flat. This means that environmental factors, such as temperature swings in the morning and at night, will not affect high-resolution positioning and screening.



High-resolution Digital Proximity Sensor with Separate Amplifier E2C-EDA Series

## **Amplifiers**

#### ■ Simple and Reliable Measurements with Micron-level Resolution Industry First

#### Two Clear, Large, and Easy-to-Read Digital Displays

The E2C-EDA features two large, easy-to-read digital displays. Since the digitized detected and threshold values can be checked at the same time, settings are simple and reliable for just about anyone. Various teaching methods are also available for settings that cannot be made consistently by different operators.

#### Digital Display Simplifies Installation and Settings

In the stable sensing zone, the E2C-EDA generally reads 1,500 or higher (see note 2). This way you can tell at a glance whether the current installation and settings are within the optimal range.

Note 2: This reading is only a guideline because there may be some variation between Sensors. Also refer to the *Engineering Data* because values may vary with non-standard objects.




A Shielded Connector is used for more reliable wiring and easier cable handling. Since the press-fit connector allows repeat connections, wiring and head replacement are simple and reliable.

#### ■ Support for High-resolution Positioning and Screening Patent pending

#### Fine Positioning Maximizes Digital Changes


Fine Positioning maximizes changes in the digital value as you get closer to the sensing point. More precise sensing can be achieved by executing Fine Positioning with the workpiece positioned at the point to be maximized.



# Smart Functions for High-resolution Parts and Assembly Inspection Applications


## **Applications**

#### Screening



#### **Digital Display**

The E2C-EDA can visually recognize height and material differences simply and reliably even with the most demanding settings.




#### Height inspection




#### **Area Output (Twin-output Type)**

An OK/NG result is easily obtained because the E2C-EDA outputs a signal between two threshold values.





#### Height inspection




#### **Mutual Interference Prevention**


The E2C-EDA has a mutual interference prevention function that uses intermittent sensing via optical communications to enable up to 5 Sensors to be combined very closely together. This feature enables multiple measurements to be made in a machine or process.







## Gap inspection



#### **Zero Reset (Fixed Threshold)**


When using a fixed sensing gap (threshold), the origin and reference position can be corrected quite simply if needed, such as when changing the process being performed.



#### ■ Simple and Common Sensor Operation in Devices

#### Platform Concept Ensures Common Operation and Programming Devices

The basic functions and Programming Devices like the Mobile Console are the same for the E2C-EDA as they are for the E3X-DA-S Digital Fiber Sensor and the E3C-LDA Laser-type Photoelectric Sensor. Just select the right type of E2C-EDA for the application, and the rest is easy.



## **Ordering Information**

#### ■ Sensors

#### **Sensor Heads**

Туре	Α	ppearance	Sensing distance	Repeat accuracy	Model
Shielded		3 dia. × 18 mm	0.6 mm	1 μm	E2C-EDR6-F (See note 2.)
	Cylindrical	5.4 dia. × 18 mm	1 mm	1 μm	E2C-ED01-□ (See notes 1, 2, and 3.)
		8 dia. × 22 mm	2 mm	2 μm	E2C-ED02-□ (See notes 1, 2, and 3.)
	Screw	M10 × 22 mm		2 μm	E2C-EM02-□ (See notes 1, 2, and 3.)
			2 mm		
	Flat	30 × 14 × 4.8 mm	5 mm	2 μm	E2C-EV05-□ (See notes 1, 2, and 3.)
Unshielded	Screw	M18 × 46.3 mm		5 μm	E2C-EM07M-□ (See notes 1, 2, and 3.)
			7 mm		
Heat-resistant	Screw	M12 × 22 mm		2 μm	E2C-EM02H (See note 2.)
	GCIEW		2 mm		

Note 1. A Protective Spiral Tube is provided with models ending in the suffix -S. (example: E2C-ED01-S).

- 2. Two cable lengths are available. (3-dia.: free-cut type, Heat-resistant type: standard-length only).

  Overall length of the standard-length type: 2.5 m, Length from the Sensor Head to the Preamplifier: 2.0 m (Example: E2C-ED01)

  Overall length of the free-cut type: 3.5 m, Length from the Sensor Head to the Preamplifier: 0.5 m for models ending in the suffix -F (example: E2C-ED01F).
- 3. Models ending in the suffix -S that come with Protective Spiral Tubes and free-cut models ending in the suffix -F are made-to-order products.

## **Amplifier Units**

#### **Amplifier Units with Cables**

	Item	Appearance	Functions	Mo	Model	
				NPN output	PNP output	
Advanced models	Twin-output models		Area output, open circuit detection, differential operation	E2C-EDA11	E2C-EDA41	
	External-input models		Remote setting, differential operation	E2C-EDA21	E2C-EDA51	

## **Amplifier Units with Connectors**

Item		Appearance	Functions	Mo	odel
				NPN output	PNP output
Advanced models	Twin-output models		Area output, open circuit detection, differential operation	E2C-EDA6	E2C-EDA8
	External-input models		Remote setting, differential operation	E2C-EDA7	E2C-EDA9

## **Amplifier Unit Connectors (Order Separately)**

-	•	-	• ,	
Item	Appearance	Cable length	No. of conductors	Model
Master Connector		2 m	4	E3X-CN21
Slave Connector			2	E3X-CN22

**Connector Ordering Precaution** 

Amplifier Units and Connectors are sold separately.

Refer to the following tables when placing an order.

Amplifier Unit					
Model NPN output PNP output					
Advanced models	E2C-EDA6	E2C-EDA8			
	E2C-EDA7	E2C-EDA9			

Applicable Connector (Order Separately)				
Master Connector	Slave Connector			
E3X-CN21	E3X-CN22			

When Using 5 Amplifier Units

Amplifier Units (5 Units)

1 Master Connector 4 Slave Connectors

## **Mobile Console (Order Separately)**

_		-
Appearance	Model	Remarks
	E3X-MC11-SV2 (model number of set)	Mobile Console with Head, Cable, and AC adapter provided as accessories
	E3X-MC11-C1-SV2	Mobile Console
	E3X-MC11-H1	Head
	E39-Z12-1	Cable (1.5 m)

Note: Use the E3X-MC11-SV2 Mobile Console with E2C-EDA-series Amplifier Units. If you use a Mobile Console like the E3X-MC11-S, some functions may not operate.

## **Accessories (Order Separately)**

#### **Mounting Bracket**

Appearance	Model	Quantity
	E39-L143	1

#### **End Plate**

Appearance	Model	Quantity
05	PFP-M	1

## **Specifications**

## **Sensor Heads**

		Model	E2C-EDR6-F	E2C-ED01(-□)	E2C-ED02(-□)	E2C-EM02-□)	E2C-EM07(-□)	E2C-EV05(-□)	E2C-EM02H
Item			3 dia. $\times$ 18 mm	5.4 dia. $\times$ 18 mm	8 dia. × 22 mm	M10 × 22 mm	M18 × 46.3 mm	$30\times14\times4.8~\text{mm}$	M12 × 22 mm
Sensing distance			0.6 mm	1 mm	2 mm		7 mm	5 mm	2 mm
Sensing object			Magnetic metal Data on page 1		istance will decre	ease when sens	ing non-magneti	ic metal. Refer to	Engineering
Standard s	ensing o	bject	$5 \times 5 \times 3 \text{ mm}$		$10 \times 10 \times 3 \text{ mm}$		$22 \times 22 \times 3 \text{ mm}$	$15 \times 15 \times 3 \text{ mm}$	$20 \times 20 \times 3 \text{ mm}$
			Material: iron (S	S50C)					
Repeat acc (See note 1			1 μm		2 μm		5 μm	2 μm	
Hysteresis	distance	)	Variable						
Tempera- ture char-	Sensor I		0.3%/°C	0.08%/°C				0.04%/°C	0.2%/°C
acteristic (See note 1.)	Preampl Amplifie		0.08%/°C						
Ambient tempera- ture (See	Operatin	g	–10°C to 60°C	(with no icing or					-10°C to 200°C (See note 3.)
Storage			-10°C to 60°C (with no icing or condensation)  (with no icing or condensation)						
Ambient h	umidity		Operating/storage: 35% to 85% (with no condensation)						
Insulation	resistanc	e	50 MΩ min. (at 500 VDC)						
Dielectric s	strength				in between curre				
Vibration re	esistance	•			ım double amplit		each in X, Y, an	d Z directions	
Shock resi	stance		Destruction: 50	0 m/s <sup>2</sup> for 3 time	es each in X, Y,	and Z directions			
Degree of p	protection	n	IEC60529 IP67						IEC60529 IP60 (See note 4.)
Connection	n method		Connector (star "-F" model cabl	ndard cable leng e length: 3.5 m	gth: 2.5 m (2 m b (0.5 m between	etween Head ar Head and Prean	nd Preamplifier) nplifier)		
Weight (pa	cked stat	te)	Approx. 120 g (	Approx. 120 g (Models with protective spiral tube ("-S" models) are approx. 90 g heavier.)					
Material			Zinc	Brass					
Head Sensing surface		Sensing surface	Heat-resistant ABS				PEEK		
		Clamp- ing nut				Nickel-plated b	rass		Nickel-plated brass
		Toothed washer				Zinc-plated iror	1		Zinc-plated iron
	Preampl	ifier	PES	PES					
Accessorie	es		Preamplifier Mo	ounting Brackets	s, Instruction Mar	nual			
Nata 4 Tha						1 1 1 11			

Note 1. The repeat accuracy and temperature characteristic are for a standard sensing object positioned midway through the rated sensing distance.

<sup>2.</sup> A sudden temperature rise even within the rated temperature range may degrade characteristics.

<sup>3.</sup> For the Sensor Head only without the preamplifier (-10 to  $60^{\circ}$ C). With no icing or condensation.

<sup>4.</sup> Do not operate in areas exposed to water vapor because the enclosure is not waterproof.


## **Amplifier Units**

-	Туре	Advanced Models	with Twin Outputs	Advanced Mod	dels with External Inputs	
Model	NPN output	E2C-EDA11	E2C-EDA6	E2C-EDA21	E2C-EDA7	
Item	PNP output	E2C-EDA41	E2C-EDA8	E2C-EDA51	E2C-EDA9	
Supply voltage	ти отрас	12 to 24 VDC ±10%, ripple				
Power consum	otion	1,080 mW max. (current co	W 17	er supply voltage of 24	VDC)	
Control output	<u> </u>	,	<u> </u>	117 0	it; load current: 50 mA max.	
·	<u> </u>	(residual voltage: 1 V max.	)	Topon conceter cutpu	nt, load dullett. do mir t max.	
Response time	Super-high- speed mode	150 μs for operation and re	eset respectively			
	High-speed mode	300 μs for operation and re	eset respectively			
	Standard mode	1 ms for operation and res	et respectively			
	High- resolution mode	4 ms for operation and res	et respectively			
Functions	Differential de- tection	Switchable between single Single edge: Can be set to Double edge: Can be set to	300 μs, 500 μs, 1 ms, 10	ms, or 100 ms		
	Timer function  Select from OFF-delay, ON-delay, or one-shot timer.  1 ms to 5 s (1 to 20 ms set in 1-ms increments, 20 to 200 ms set in 10-ms increments, 20 to 200 ms set in 10-ms increments, 200 ms to 1 s set in 100-ms increments, and 1 to 5 s set in 1 s-increments)					
	Zero-reset	Negative values can be dis	splayed. (Threshold is not s	shifted.)		
	Initial reset	Settings can be returned to defaults as required.				
	Mutual interfer- ence preven- tion	Possible for up to 5 Units. (See note.) Intermittent oscillation method (Response time = (number of Units connected + 1) ×15 ms)				
	Hysteresis set- tings	Setting range: 10 to 4,000				
	I/O settings	Output setting (Select from output, self-diagnosis, or o		Input setting (Select f zero-reset, synchrono	rom teaching, fine positioning, ous detection.)	
Digital display		Select from the following: Incident level + threshold, incident level percentage +threshold, incident light peak level + incident light bottom level (updated with output), long bar display, incident level + peak hold, incident level + channel				
Display orienta	tion	Switching between normal/reversed display is possible.				
Ambient tempe	rature	Operating:  When connecting 1 to 2 Units: -10°C to 55°C  When connecting 3 to 5 Units: -10°C to 50°C  When connecting 6 to 16 Units: -10°C to 45°C				
		When used in combination with an EDR6-F When connecting 3 to 4 Units: -10°C to 50°C When connecting 5 to 8 Units: -10°C to 45°C When connecting 9 to 16 Units: -10°C to 40°C				
		Storage: –20°C to 70°C (with no icing)				
Ambient humid	ity	Operating/storage: 35% to 85% (with no condensation)				
Insulation resis	tance	20 MΩ min. (at 500 VDC)				
Dielectric stren	gth	1,000 VAC at 50/60 Hz for 1 min				
Vibration resist	ance	Destruction: 10 to 55 Hz, 1.5-mm double amplitude for 2 hours each in X, Y, and Z directions				
Shock resistand	ce	Destruction: 500 m/s² for 3 times each in X, Y, and Z directions				
Degree of prote	ction	IEC60529 IP50				
Connection me		Prewired	Connector	Prewired	Connector	
Weight (packed		Approx. 100 g	Approx. 55 g	Approx. 100 g	Approx. 55 g	
Material	Case	PBT (polybutylene terepht)		<u> </u>		
	Cover	Polycarbonate	·			
		1				


Note: Communications are disabled if the detection mode is selected during super-high-speed sensing mode, and the communications functions for mutual interference prevention and the Mobile Console will not function.

## **Engineering Data**


## Sensing Distance vs. Display Values



## **Influence of Sensing Object Size and Material**




#### **Influence of Sensor Head Temperature**



## **Operation**

#### **NPN Output**




Note 1. Setting Areas for Twin-output Models

Normally open: ON between the thresholds for Channel 1 and Channel 2 Normally closed: OFF between the thresholds for Channel 1 and Channel 2

2. Timing Charts for Timer Settings (T: Set Time)

ON delay	OFF delay	One shot
Sensing Yes object No ON OFF ON OFF ON OFF	Sensing Yes object No ON OFF ON OFF OFF	Sensing No ON OFF OFF

#### **PNP Output**



Note 1. Setting Areas for Twin-output Models

Normally open: ON between the thresholds for Channel 1 and Channel 2 Normally closed: OFF between the thresholds for Channel 1 and Channel 2

2. Timing Charts for Timer Settings (T: Set Time)


ON delay	OFF delay	One shot	
Sensing Yes object No ON OFF ON OFF	Sensing Yes object No ON OFF THE NO OFF	Sensing No OFF THE NC OFF	

## **Nomenclature**

#### **Amplifier Units**


#### **Twin-output Models**

(E2C-EDA11/EDA41/EDA6/EDA8)



#### **External-input Models**

(E2C-EDA21/EDA51/EDA7/EDA9)



## **Precautions**

#### ∕!\ WARNING

Do not use this product in any safety device used for the protection of human lives.



#### **Precautions for Correct Use**

Do not use this product in operating atmospheres or environments outside the specified ratings.

#### **Amplifier Units**

#### Design


#### **Power ON**

The Sensor is ready to sense an object within 200 ms after turning the power ON. If the load and Sensor are connected to different power supplies, always turn ON the Sensor power first.


#### Connecting Sensor Heads

#### **Connecting and Disconnecting Sensor Heads**

- 1. Open the protective cover.
- Making sure that the lock button is up, insert the fibers all the way to the back of the Connector insertion opening.




To disconnect the Sensor Head, pull out the fibers while pressing on the lock button.



#### **Connecting and Disconnecting Connectors**

#### **Connecting Connectors**

 Insert the Master or Slave Connector into the Amplifier Unit until it clicks into place.




Apply the supplied seal to the non-connection surface of the Master/Slave Connector.



Note: Apply the seal to the grooved side.

#### **Disconnecting Connectors**

- 1. Slide the Slave Amplifier Unit.
- After the Amplifier Unit has been separated, press down on the lever on the Connector and remove it. (Do not attempt to remove Connectors without separating them from other Amplifier Units first.)



#### **Installing and Removing Amplifier Units**


#### **Installing Amplifier Units**

1. Install the Units one by one to the DIN rail.



Sensor Head Connector Clips

2. Slide one Unit toward the other, match the clips at the front ends, and then bring them together until they "click."




#### **Removing Amplifier Units**

Slide one Unit away from the other and remove them one by one. (Do not remove the connected Units together from the DIN rail.)

- Note 1. When the Amplifier Units are connected to each other, the operable ambient temperature changes depending on the number of connected Amplifier Units. Check Specifications.
  - 2. Before connecting or disconnecting the Units, always switch power OFF.


#### **End Plate Mounting (PFP-M)**

Mount End Plates on Amplifier Units to avoid movement due to vibration. When a Mobile Console is installed, mount the End Plate facing as shown in the following diagram.



## Mounting a Communications Head for the Mobile Console

Leave a space of at least 20 mm on the left side of the Units for a Mobile Console Communications Head.



#### **EEPROM Write Error**

If the data is not written to the EEPROM correctly due to a power failure or static-electric noise, initialize the settings using the keys on the Amplifier Unit.

#### **Optical Communications**

When using more than one Amplifier Unit, mount the Units side-byside. Do not slide or remove Units while they are in use.

#### Miscellaneous

#### **Protective Cover**

Be sure to put on the Protective Cover before use.

#### **Mobile Console**

Use the E3X-MC11-SV2 Mobile Console for E2C-EDA-series Amplifier Units. Other Mobile Consoles, such as the E3X-MC11, cannot be used.

#### **Sensor Head and Amplifier Unit Connection**

Be sure to use only specified Sensor Head and Amplifier Unit combinations. The E3C-LDA-series Photoelectric Sensor with Separate Digital Amplifier is not compatible, and the E2C-EDA must not be used with products from that series.

#### Warm-up

The digital display will slowly change until the circuits stabilize after the power is turned ON. It takes about 30 minutes after the power is turned ON before the E2C-EDA is ready to sense.

#### **Maintenance Inspection**

- Be sure to turn OFF the power before adjusting, connecting, or disconnecting the Sensor Head.
- Do not use thinner, benzene, acetone, or kerosene to clean the Sensor Head or Amplifier Unit.


#### **Sensor Heads**

#### Mounting

#### **Mounting Sensor Heads**

 Use the dimensions from the following table to mount unthreaded cylindrical models (E2C-ED-□□). Do not tighten screws with torque exceeding 0.2 N·m when mounting Sensor Heads.

Model	Tightening range A	
	9 to 18 mm	
	9 to 18 mm	
	11 to 12 mm	



 Use the torque given in the following table to tighten threaded cylindrical models (E2C-EM□□).

Model	Tightening torque	
E2C-EM02□□	15 N⋅m max.	
E2C-EM07M□□	15 N⋅m max.	
E2C-EM02H□□	5.9 N·m max.	


- Do not use torque exceeding 0.5 N⋅m to tighten screws when mounting flat models (E2C-EV□□).
- Use a bending radius of at least 8 mm for the Sensor Head cable.
- Use only the special extension cable to extend the cable between the Sensor Head and the Amplifier Unit. Consult your OMRON representative for details.

#### **Effects of Surrounding Metal**

 Provide a minimum distance between the Sensor and the surrounding metal as shown in the table below.

Effects of Surrounding Metal (Units: mm)

Model	Counterbore A	Protrusion B
E2C-EDR6-F	3.1	0
E2C-ED01□□	5.4	0
E2C-ED02□□	8	0
E2C-EM02□□	10	0
E2C-EM07M□□	35	20
E2C-EV05□□	14 × 30	4.8
E2C-EM02H□□	12	0



#### **Mutual Interference**

- If more than one Sensor Head is installed face to face or in parallel, make sure that the distances between two Units adjacent to each other are the same as or larger than the corresponding values shown in the following table.
- The distance between Sensor Heads may be narrower than specified with these Sensors because the Mutual Interference Prevention Function is used for optical communications between the Amplifier Units.



Mutual Interference

(Units: mm)

Model	Face-to- face arrange- ment A	Parallel arrange- ment B	Face-to-face arrangement using the Mutual Interference Prevention Function A'	Parallel arrangement using the Mutual Interference Prevention Function B'
E2C-EDR6-F	14	10	3.5	3.1
E2C-ED01□□	45	20	9	5.4
E2C-ED02□□	35	30	21	8
E2C-EM02□□	36	30	21	10
E2C-EM07M□□	140	120	35	18
E2C-EV05□□	65	30	21	14
E2C-EM02H□□	45	30	21	12


## **Dimensions**

#### **Sensors**

#### E2C-EDR6-F










E2C-ED01(-F)











E2C-ED02(-F)










#### E2C-EM02(-F)






15→ 20.6-






#### E2C-EM07M(-F)



#### E2C-EV05(-F)




#### E2C-EM02H











## **■** Amplifier Units

## **Amplifier Units with Cables**




## **Amplifier Units with Connectors**

E2C-EDA6 E2C-EDA7 E2C-EDA8 E2C-EDA9












#### With Mounting Bracket Attached



#### OMRON

#### OMROD

#### **READ AND UNDERSTAND THIS DOCUMENT**

Please read and understand this document before using the products. Please consult your OMRON representative if you have any questions or comments.

#### **WARRANTY**

OMRON's exclusive warranty is that the products are free from defects in materials and workmanship for a period of one year (or other period if specified) from date of sale by OMRON.

OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, REGARDING NON-INFRINGEMENT, MERCHANTABILITY, OR FITNESS FOR PARTICULAR PURPOSE OF THE PRODUCTS. ANY BUYER OR USER ACKNOWLEDGES THAT THE BUYER OR USER ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. OMRON DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED.

#### LIMITATIONS OF LIABILITY

OMRON SHALL NOT BE RESPONSIBLE FOR SPECIAL, INDIRECT, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED ON CONTRACT, WARRANTY, NEGLIGENCE, OR STRICT LIABILITY.

In no event shall responsibility of OMRON for any act exceed the individual price of the product on which liability is asserted.

IN NO EVENT SHALL OMRON BE RESPONSIBLE FOR WARRANTY, REPAIR, OR OTHER CLAIMS REGARDING THE PRODUCTS UNLESS OMRON'S ANALYSIS CONFIRMS THAT THE PRODUCTS WERE PROPERLY HANDLED, STORED, INSTALLED, AND MAINTAINED AND NOT SUBJECT TO CONTAMINATION, ABUSE, MISUSE, OR INAPPROPRIATE MODIFICATION OR REPAIR.

#### **SUITABILITY FOR USE**

THE PRODUCTS CONTAINED IN THIS DOCUMENT ARE NOT SAFETY RATED. THEY ARE NOT DESIGNED OR RATED FOR ENSURING SAFETY OF PERSONS, AND SHOULD NOT BE RELIED UPON AS A SAFETY COMPONENT OR PROTECTIVE DEVICE FOR SUCH PURPOSES. Please refer to separate catalogs for OMRON's safety rated products.

OMRON shall not be responsible for conformity with any standards, codes, or regulations that apply to the combination of products in the customer's application or use of the product.

At the customer's request, OMRON will provide applicable third party certification documents identifying ratings and limitations of use that apply to the products. This information by itself is not sufficient for a complete determination of the suitability of the products in combination with the end product, machine, system, or other application or use.

The following are some examples of applications for which particular attention must be given. This is not intended to be an exhaustive list of all possible uses of the products, nor is it intended to imply that the uses listed may be suitable for the products:

- · Outdoor use, uses involving potential chemical contamination or electrical interference, or conditions or uses not described in this document.
- Nuclear energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equipment, and installations subject to separate industry or government regulations.
- Systems, machines, and equipment that could present a risk to life or property.

Please know and observe all prohibitions of use applicable to the products.

NEVER USE THE PRODUCTS FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

#### PERFORMANCE DATA

Performance data given in this document is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of OMRON's test conditions, and the users must correlate it to actual application requirements. Actual performance is subject to the OMRON Warranty and Limitations of Liability.

#### **CHANGE IN SPECIFICATIONS**

Product specifications and accessories may be changed at any time based on improvements and other reasons.

It is our practice to change model numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the product may be changed without any notice. When in doubt, special model numbers may be assigned to fix or establish key specifications for your application on your request. Please consult with your OMRON representative at any time to confirm actual specifications of purchased products.

#### **DIMENSIONS AND WEIGHTS**

Dimensions and weights are nominal and are not to be used for manufacturing purposes, even when tolerances are shown.

#### **ERRORS AND OMISSIONS**

The information in this document has been carefully checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical, or proofreading errors, or omissions.

#### PROGRAMMABLE PRODUCTS

OMRON shall not be responsible for the user's programming of a programmable product, or any consequence thereof.

#### **COPYRIGHT AND COPY PERMISSION**


This document shall not be copied for sales or promotions without permission.

This document is protected by copyright and is intended solely for use in conjunction with the product. Please notify us before copying or reproducing this document in any manner, for any other purpose. If copying or transmitting this document to another, please copy or transmit it in its entirety.

A host of remarkable functions inside a compact body. A complete lineup of sensor heads to handle an even wider range of applications. This is the platform for OMRON's sensing technology.

#### **Linear Platform**

High-resolution sensing using laser and magnetic technology.



#### Laser-type Smart Sensors ZX-L Series



An improved lineup for smarter sensing.

E3X-DA-S Series/MDA Series

Digital Fiber Sensors

#### Inductive Displacement Smart Sensors ZX-E Series



A lineup of Smart Sensors that use the eddy

Laser-type Photoelectric Sensors with Separate Digital Amplifiers E3C-LDA Series

#### **ON/OFF Platform**

A common platform for Fiber Sensors and Sensors with Separate Amplifiers.



Refinement and a new generation that goes



Photoelectric Sensors with Separate Digital

- Never use the products for any application requiring special safety requirements, such as nuclear energy control systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equipment, or other application involving serious risk to life or property, without ensuring that the system as a whole has been designed to address the risks, and that the OMRON products are properly rated and installed for the intended use within the overall equipment or system.

### **OMRON Corporation**

**Industrial Automation Company** 

Sensing Devices Division H.Q. Application Sensors Division Shiokoji Horikawa, Shimogyo-ku, Kyoto, 600-8530 Japan Tel: (81)75-344-7068 Fax: (81)75-344-7107

#### Regional Headquarters

• The application examples provided in this catalog are for reference only. Check functions and safety of the equipment before use.

#### OMRON EUROPE B.V.

Sensor Business Unit, Carl-Benz-Str. 4, D-71154 Nufringen, Germany Tel: (49)7032-811-0/Fax: (49)7032-811-199

#### **OMRON ELECTRONICS LLC**

1 East Commerce Drive, Schaumburg, IL 60173 U.S.A. Tel: (1)847-843-7900/Fax: (1)847-843-8568

OMRON ASIA PACIFIC PTE. LTD. 83 Clemenceau Avenue, #11-01, UE Square, 239920 Singapore

Tel: (65)6835-3011/Fax: (65)6835-2711

#### OMRON (CHINA) CO., LTD.

Room 2211, Bank of China Tower, 200 Yin Cheng Road (M), Shanghai, 200120 China Tel: (86)21-5037-2222/Fax: (86)21-5037-2200

#### **Authorized Distributor:**